

FR90

Report No. 17-003147-PR01

IFT NB 0757 CPR No 305/2011

Double sash door outside open with top and side light

S x H – 4827 x 4280 mm

Researches		Requirements	Classification standard
Properties	Test method	Classification	Reference document
Air permeability	PN-EN 1026:2001	Class 4	PN-EN 12207:2001
Watertightness	PN-EN 1027:2001	4A(150Pa)	PN-EN 12208:2001
Resistance to wind load	PN-EN 12211:2001	C1(400Pa)/B2(800Pa)	PN-EN 12210:2001
Fire resistance	EN 1634-1:2014-03+Ap1:2016-10	EI15, EI30, EI45, EI60	EN 13501-2:2016-07

Sash dimension	1076x2576 mm
Profiles	FR101, FR102, FR103,GT692

